


WELL DRILLING  
ADVISORY SERVICE  
WELL TESTING



6116 FOURTH AVENUE SO.  
SEATTLE 8, WASH.

OFFICE:  
PA 2-2466  
RESIDENCE:  
CH 2-8271

Island County  
WATER WELL REPORT

29N-02E-14C

October 13, 1967

Ideal Investments, Inc.  
Box 223  
Clinton, Washington 98236

# 1

Well Log

0	-	8	Fill
8	-	30	Brown clay and sand
30	-	61	Blue clay and silt
61	-	171	Brown clay and sand
171	-	185	Brown sand
185	-	208	Coarse brown sand and gravel, water bearing

5' of 6" No. 16 slot Johnson Everdur screen with  
4" ball-down fittings. 6' of 5" pipe on top with  
figure K packer.

Total depth of well 208'  
Static water level 178' pumping 15 G.P.M.  
Draw-down of 3'